

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 12/12/2023

It is certified that an inspection team headed by RAHUL KHAN Junior Engineer
(Name of Officers with designation) from Municipal Corporation Gurugram
(Name of Department/ Office) inspected the BUDDHA INTERNATIONAL SCHOOL, JAIL ROAD NAYAGRAH
(Name & Address of the school) on 07-12-2023 (date of inspection), checked the water test report
submitted by the school and found that the school has potable drinking water for students and staff of the
institution and is having provision for running water in the toilets and maintaining hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
The above is valid for a period of 1 year

Signature with Seal: [Signature]

Name : VIKKY

Designation : Executive Engineer
Municipal Corporation
Gurugram

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department : M.C.C.

To

BUDDHA INTERNATIONAL SCHOOL

JAIL ROAD NAYAGRAH (STONDER)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
GURUGRAM
TEST REPORT



Test Report No.:- GGN/01711/12/2023 Issued to :-Buddha International School, Gurugram Your Reference No. :- spl dated: 07/12/2023 Sample Type:- Chemical Test Name of JE :----- Lab Job Order No. :-1711	Issue Date:- 08/12/2023 Location:-T/W, Buddha International School, Naya Gaon, Gurugram Collected by :-Rupender Sample collected on &Time:- 07/12/2023 Sample received on:- 07/12/2023 Sample Quantity: 1000 ml
---	--


Test Result

Test started on- 07/12/2023				Test completed on – 08/12/2023		
S No.	Tested Parameter	Results	Unit	Method	Acceptable	Permissible Limit (As per IS 10500:2012) RA 2018
1	Turbidity	1	NTU	APHA2130 B	1 NTU	5 NTU
2	Taste	Agreeable	-	APHA-2160-C	Agreeable	Agreeable
3	Odour	Agreeable	-	APHA-2150-B	Agreeable	Agreeable
4	Colour	1	HU	APHA 2120-B	5 HU	15 HU
5	Total Dissolved Solids @180°C	1570	mg/l	APHA2540 C	500 mg/l	2000 mg/l
6	Total Hardness as CaCO3	1015	mg/l	APHA2340 C	200 mg/l	600 mg/l
7	Calcium as (Ca)	244	mg/l	APHA3500-Ca B	75 mg/l	200 mg/l
8	Magnesium as (Mg)	97.2	mg/l	APHA3500 Mg B	30 mg/l	100 mg/l
9	Alkalinity	200	mg/l	APHA2320 B	200 mg/l	600 mg/l
10	Chloride as Cl	850	mg/l	APHA 4500 Cl-B	250 mg/l	1000 mg/l
11	Sulphate as (So4)	71.17	mg/l	APHA 4500-So4- E	200 mg/l	400 mg/l
12	Fluoride as (F)	0.59	mg/l	APHA 4500-D	1.0 mg/l	1.5 mg/l
13	Iron as (Fe)	0.14	mg/l	APHA 3500-Fe B	1.0 mg/l	No Relaxation
14	Nitrate as (No3)	2.59	mg/l	APHA 4500-No3 ⁻ B	45 mg/l	No Relaxation
15	PH@25°C	7.61	---	APHA 4500-H+ B	6.5-8.5	No Relaxation
16	Conductivity	---	µs	APHA-2510-B		

Specific contractual notes: -

- ◆ The results given above are related to the sample as received and tested in PHED Lab Gurugram.
- ◆ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab Gurugram.
- ◆ The test report can't be used for any publicity or any legal purpose.
- ◆ The samples received shall be destroyed after 15 Days from the date of issue of the certificate.
- ◆ Reliability of water sample lies with sender/collector of water sample.

Reviewed by


 Authorised Signatory (Kanta Punia)
 Chemist
 PHED Water Testing Laboratory
 Gurugram